


ANNUAL FIRE-FIGHTING EQUIPMENT CERTIFICATE

Property Address: 101/4 (1F2) Sighthill Loan, Edinburgh, EH11 4NT

Client: Johnston & Stevens, 6A Hart Street, Edinburgh, EH1 3RN

Date Issued: 26/Feb/26 **Valid Until:** 25/Feb/27

Issued By: Gordon Johnston (07799 653 614)



FIRE BLANKET INSPECTION

Overall Status: Satisfactory **Check Type:** Basic
Location: Kitchen **Wall Mount:** Yes
Size: 1.2m x 1.2m **Make & Model:** SecureFix Direct
Comments: None

Checks

External Exam: OK	Deployment: OK	Operating Instructions: OK
Visual Inspection: OK	Re-Assembly: OK	Maintenance Label: OK
Age: OK	Installed: Mar/24	End of Life: Mar/31

FIRE EXTINGUISHER CERTIFICATE OF INSPECTION BS 5306-3:2009

Overall Status: Satisfactory **Check Type:** Comprehensive
Location: Hall **Wall Mount:** Yes
Size: 2 Litre (13A, 55B) **Make & Model:** Britannia P50 Foam
Serial No: F2-174284 **Comments:** None

Checks

Body Damage: OK	Base Ring: OK	Operating Instructions: OK
Tamper Seal: OK	Hose: N/A	Nozzle Blockage: OK
Handle: OK	Cleaned: OK	Pressure Gauge & Test: OK
Age: OK	Installed: Mar/21	End of Life or Refurb: Mar/31

Notes: Britannia P50 foam fire extinguishers are certified for use on Class A (solid combustibles) and Class B (flammable liquid) fires. P50 foam extinguishers are safe to use around live electrical equipment (up to 1kV from a distance of 1m).